

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:01 pm

PWS ID: UTAH10037 **Name:** RED CLIFFS RANCH WATER
Legal Contact: RED CLIFFS RANCH WATER **Rating:** Approved
COLIN FRYER **Rating Date:** 06/04/2009
Address: MILE POST 14 HWY 128 **Activity Status:** Active
MOAB, UT 84532
Phone Number: 435-259-6171
City Served (Area):
County: GRAND COUNTY

System Type: Non-community **Last Inv Update:** 06/10/2010 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 10/08/2008 **Total Dsgn Cap:**
Population: 30 **Surveyor:** MARK E HANSEN **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers	Emergency	Email Address
AC	FRYER, COLIN				sandy@redcliffslodge.com

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Commercial	Unknown	0	1
Residential	Unknown	0	1
			<u>2</u> Total Svc Connections

Storage

Total Storage: 40,000 GAL **Number of Units:** 2 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST001	RED CLIFFS RANCH STORAGE TAN	Ground	20,000 GAL	Fiberglass		A	NO
ST002	STORAGE TANK 2	Ground	20,000 GAL	Fiberglass		A	NO

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	RANCH WELL FILTER PLANT		A	

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	RANCH WELL	Active	WL	6	80 GPM	75 GPM	Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.